



GG00180A

| Above-ground Opaque Building Assembly | Heating Degree-Days of <i>Building Location</i> , ⁽¹⁾ in Celsius Degree-Days | | | | | |
|---|---|--|--|---|---|----------------------------------|
| | Zone 4: ⁽²⁾ < 3000 | Zone 5: ⁽²⁾ 3000 to 3999 | Zone 6: ⁽²⁾ 4000 to 4999 | Zone 7A: ⁽²⁾ 5000 to 5999 | Zone 7B: ⁽²⁾ 6000 to 6999 | Zone 8: ⁽²⁾ ≥ 7000 |
| | Maximum Overall Thermal Transmittance, $W/(m^2 \times K)$ | | | | | |
| Walls | 0.290 | 0.265 | 0.240 | 0.215 | 0.190 | 0.165 |
| Roofs | 0.164 | 0.156 | 0.138 | 0.121 | 0.117 | 0.110 |
| Floors | 0.193 | 0.175 | 0.156 | 0.138 | 0.121 | 0.117 |